

Renishaw plc
New Mills, Wotton-under-Edge,
Gloucestershire GL12 8JR
United Kingdom

Tel +44 (0) 1453 524524
Fax +44 (0) 1453 524901
Email uk@renishaw.com
www.renishaw.com

RENISHAW 
apply innovation™



FUNCTIONAL SAFETY CERTIFICATE

Renishaw plc declares that, under the terms of CSA SIRA functional safety certificate SIRA CASS00023, for the management of functional safety activities up to SIL3/PLd, that:

- All length options and mounting options for the FORTiS-S™ FS and FORTiS-N™ FS variants,
- when used with the BiSS® Safety or Siemens DRIVE-CLiQ™ protocol options, and
- when used with Renishaw approved cables,

have been independently assessed by the Renishaw plc Functional Safety Authority and have been found to meet the requirements of:

- IEC 61508-1:2010, IEC 61508-2:2010 and IEC 61508-3:2010
- IEC 61800-5-2:2016
- ISO 13849-1:2015 and ISO 13849-2:2012

when used as an element / subsystem for use in safety related systems performing safety functions up to and including:

- SIL2 with HFT = 0 (1oo1),
- Category 3, PLd.

Notes:

This product must not be put into service until it has been installed and commissioned in accordance with the instructions detailed by the FORTiS™ FS Installation Guide and Safety manuals M-6725-9026 FORTiS-N FS IG [EN] / M-6725-9016 FORTiS-S FS IG [EN]

For full details of the safety function, the functional safety data, fault exclusions and the limitations of use, see the above documents which can be accessed at www.renishaw.com/fsencoders.

The person authorised to conduct the functional safety assessment and issue the functional safety certificate is:

Martin Curtis, Functional Safety Authority (Encoder Products Division)
Renishaw PLC, New Mills, Wotton-under-Edge, Gloucestershire, GL12 8JR, United Kingdom.

09/03/2026

X 

Martin Curtis
Functional Safety Authority (EPD)
Signed by: Martin Curtis

Place: Wotton-under-Edge.

This certificate is valid until 10/03/2031.

Functional safety certificate number FSC003-02

Page 1 of 1